TRIDONIC

HID control gear Electronic

PCI C521 Single GST

PCI PRO independent

HI

Product description


- · For metal halide lamps
- Also for mobile luminaires with connectors
- Pulse packets for increased ignition energy (pulseCONTROL technology)
- With patented circuit elements
- · Halogen-free lamp cable with GST18 socket and interlock lug
- Flicker-free light
- Colour stability thanks to constant power
- Guaranteed long life
- No acoustic resonance
- Safety shutdown if a lamp is faulty or missing
- Greatly reduced reignition time
- Hardly any EMC interference in the ignition phase
- Automatic shutdown on overheating
- Through wiring possible
- No tools required for installing the terminal cover and cable clamps
- Push-in terminals up to 2.5 mm²
- 3 separate strain reliefs
- Casing: polycarbonate, black

Technical data

 \rightarrow

Mains voltage range	220 – 240 V
AC voltage range	198 – 254 V
DC voltage range	198 – 320 V
Mains frequency	0 / 50 / 60 Hz
Max. ignition voltage	5 kVp (2 kVp at 22 W)
Operating frequency	145 Hz
Type of protection	IP20

Wiring diagrams and installation examples, page 2



, 1000000000000000000000000000

•125,5 —

159.4

П

Ordering data

450

Туре	Article number	Packaging, carton	Packaging, pallet	Weight per pcs.
For luminaires with 1 lamp				
PCI 20 PRO C521 GST	86459020	12 pieces	288 pieces	0.30 kg
PCI 22 PRO C521 GST	86459023	12 pieces	288 pieces	0.30 kg
PCI 35 PRO C521 GST	86458906	12 pieces	288 pieces	0.30 kg
PCI 50 PRO C521 GST	86459310	12 pieces	288 pieces	0.31 kg
PCI 70 PRO C521 GST	86458907	12 pieces	288 pieces	0.31 kg
PCI 150 PRO C521 GST	86458908	12 pieces	288 pieces	0.53 kg

Ö

Specific technical data

Standards, page 2


00000														
Lamp	Lamp	Туре	Article number	Dimensions	Lamp	Circuit	EEI	Efficiency	Current at	λ at	Max. cable	tc point	Ambient	tc/ta for ≥
wattage	type			L x W x H	power	power®			50 Hz 230 V	50 Hz 230 V	length to lamp	max.	temperature ta	50,000 h
For lumin	aires wi	ith 1 lamp												
1 x 20 W	HI	PCI 20 PRO C521 GST	86459020	159.4 x 82 x 34 mm	20 W	23.0 W	A2	> 88 %	0.10 A	0.95	2 m / 160 pF	70 °C	-25 +65 °C	70/65 °C
1 x 22 W	HI	PCI 22 PR0 C521 GST	86459023	159.5 x 82 x 34 mm	22 W	25.5 W	A2	> 88 %	0.11 A	0.95	2 m / 160 pF	70 °C	-25 +65 °C	70/65 °C
1 x 35 W	HI	PCI 35 PR0 C521 GST	86458906	159.4 x 82 x 34 mm	39 W	43.5 W	A2	> 89 %	0.20 A	0.97	5 m / 400 pF	80 °C	-25 +65 °C	80/65 °C
1 x 50 W	HI	PCI 50 PRO C521 GST	86459310	159.5 x 82 x 34 mm	50 W	55.0 W	A2	> 90 %	0.25 A	0.96	5 m / 400 pF	75 °C	-25 +60 °C	75/60 °C
1 x 70 W	HI	PCI 70 PRO C521 GST	86458907	159.5 x 82 x 34 mm	73 W	79.0 W	A2	> 90 %	0.35 A	0.97	5 m / 400 pF	75 °C	-25 +50 °C	75/50 °C
1 x 150 W	HI	PCI 150 PR0 C521 GS	6 86458908	209.4 x 82 x 34 mm	147 W	158.5 W	A2	> 91 %	0.70 A	0.97	5 m / 400 pF	80 °C	-25 +45 °C	80/45 °C
1 At ta = 25	0° C													

[⊕] At ta = 25 °

Installation instructions

Wiring type and cross section

Stranded wire or solid wire up to $2.5 \, \text{mm}^2$ may be used for wiring. Strip 10–11 mm of insulation from the cables to ensure perfect operation of the screw terminals.



Use one wire for each terminal connector only.

Use each strain relief channel for one cable only.

Lamp cable connector

Black GST-18 socket with interlock lug




Terminals Screw type M3

Torque 0.5 Nm

Fixing conditions

Dry, acidfree, oilfree, fatfree. The maximum ambient temperature must not be exceeded. Is not suitable for fixing in corner. Whenever possible keep the ballast away from hot parts. It helps increasing the lifetime of the ballast.




If several ballasts are installed in masts, boxes, etc., measures must be taken to avoid overheating of individual components.

To prevent the use of a wrong lamp type we recommend to mark the luminaire with the correct lamp type that fits to the ballast.


Note on wiring

The length of the lamp wires is limited by the value of cable capacitance. The maximum of 160/400 pF would enable connection of approximately 2/5 metres of lamp wire.

In class 1 luminaires it is necessary to earth the ballast and the luminaire, in class 2 luminaires not.



Circuit diagram PCI class 1 application



Circuit diagram PCI class 2 application

Radio interference

- Do not cross mains and lamp cables.
- Do not lay mains cables together with lamp cables (ideally they should be 5–10 cm apart).
- Do not lead mains cables too closely along the electronic ballast.
- Twist lamp cables.
- Increase the distance between lamp cables and earthed metal surfaces.
- Keep the mains cable short.
- Parallel runs (x) of mains and lamp cables must be kept as short as possible.
- Connection to earth reduces radio interference.

Important advise

When a lamp is changed (at the end of its life), if a lamp is missing or after overtemperature shutdown the mains voltage of the ECG must be disconnected.

Warning – starting voltage up to max. 5 kV!

Not suitable for use with lamps with integral ignitors.

A list of released lamps for the save operation with PCI can be found on <u>www.tridonic.com</u> \rightarrow Technical Data \rightarrow Lamp matrix \rightarrow Lamp Matrix for HID

Safety switch off

End of life of the lamps

At the end of their useful life, lamps often cycle on/ off. The PCI ballast recognises this condition and switches off the lamp, after three complete on/ off cycles and whilst the supply has been unswitched. Complete lamp switch off enables easy identification of a defective lamp in the application. After a change of the faulty lamp and an interruption of the mains supply (mains reset) the ballast will strike the lamp. When there is no lamp in circuit or a defective lamp is connected to the ballast, the ballast will switch off after apr. 25 minutes (3.5 minutes of ignition time).

Overtemperature shutdown

The units shut down at Δt approx. +12 °C compared with tc/ta. A mains reset must be carried out so that the units switch on again.

Overload strength

320 Vac / 1 h

Standards

EN 55015 (radio interference) EN 61000-3-2 (mains harmonics) EN 61347-2-12 EN 61547 (interference immunity) EN 61167 CE mark ENEC mark CQC mark

Glow-wire test according to EN 60598-1 850 °C passed

Harmonic distortion in the mains supply

	THD
Туре	at 230 V/50 Hz
PCI 20 PRO C521 GST	< 12%
PCI 22 PRO C521 GST	< 12%
PCI 35 PRO C521 GST	< 10 %
PCI 50 PRO C521 GST	< 10 %
PCI 70 PRO C521 GST	< 10 %
PCI 150 PR0 C521 GST	< 10 %

Ballast lumen factor EN 60929 8.1

	AC/DC-BLF
Туре	at U = 198–254 V, 25 °C
PCI 20 PR0 C521 GST	1.00
PCI 22 PR0 C521 GST	1.00
PCI 35 PRO C521 GST	1.00
PCI 50 PR0 C521 GST	1.00
PCI 70 PR0 C521 GST	1.00
PCI 150 PR0 C521 GST	1.00

Electronic

Loading of automatic circuit breakers

Automatic circuit breaker type	C10	C13	C16	C20	B10	B13	B16	B20
Installation Ø	1.5 mm ²	1.5 mm ²	1.5 mm ²	2.5 mm ²	1.5 mm ²	1.5 mm ²	1.5 mm ²	2.5 mm ²
PCI 20 PRO C521 GST	30	40	50	60	15	20	25	30
PCI 22 PRO C521 GST	30	40	50	60	15	20	25	30
PCI 35 PRO C521 GST	30	40	50	60	15	20	25	30
PCI 50 PRO C521 GST	14	25	36	42	8	14	18	18
PCI 70 PRO C521 GST	14	25	36	42	8	14	18	18
PCI 150 PRO C521 GST	7	14	20	20	4	6	7	7

Temperature range

The ta temperature value is the basis for specifying the rated life.

The relationship between the tc temperature and the ta temperature depends on the design of the luminaire. If the measured tc temperature is approximately 5 K under the tc max. temperature the ta temperature should be checked and, if necessary, measurements should be taken on the critical components (e.g. electrolytic capacitor).

Detailed information is available on request.

PCI PRO C521 GST is designed for an average life of 50,000 hours under rated conditions, with a failure probability of less than 10 %. This corresponds to an average failure rate of 0.2 % per 1,000 hours of operation.

The specified tc temperature is the maximum permitted value (EN 60598-1). Above this safety-related value the thermal cutout protects the device against damage.

The expected lifetime values are shown in the following table. The tc values are the relevant values here.

Isolation and electric strength testing of luminaires

Electronic devices can be damaged by high voltage. This has to be considered during the routine testing of the luminaires in production.

According to IEC 60598-1 Annex Q (informative only!) or ENEC 303-Annex A, each luminaire should be submitted to an isolation test with 500 V $_{DC}$ for 1 second. This test voltage should be connected between the interconnected phase and neutral terminals and the earth terminal. The isolation resistance must be at least 2 M Ω .

As an alternative, IEC 60598-1 Annex Q describes a test of the electrical strength with $1500 V_{AC}$ (or $1.414 \times 1500 V_{DC}$). To avoid damage to the electronic devices this test must not be conducted.

Additional information

Additional technical information at <u>www.tridonic.com</u> \rightarrow Technical Data

Guarantee conditions at <u>www.tridonic.com</u> \rightarrow Services

No warranty if device was opened.

Expected lifetime										
Туре	Lamp type	Lamp power	ta	35 °C	40 °C	45 °C	50 °C	55 °C	60 °C	65 °C
PCI 20 PRO	н	1x20 W	tc	40 °C	45 °C	50 °C	55 °C	60 °C	65 °C	70 °C
F GI ZUFNU			Lifetime	> 100,000 h	> 100,000 h	> 100,000 h	> 100,000 h	100,000 h	75,000 h	50,000 h
PCI 22 PRO	н	1x22 W	tc	40 °C	45 °C	50 °C	55 °C	60 °C	65 °C	70 °C
101221110			Lifetime	> 100,000 h	> 100,000 h	> 100,000 h	> 100,000 h	100,000 h	75,000 h	50,000 h
PCI 35 PRO	н	1x35 W	tc	50 °C	55 °C	60 °C	65 °C	70 °C	75 °C	80 °C
101331110			Lifetime	> 100,000 h	> 100,000 h	> 100,000 h	> 100,000 h	100,000 h	75,000 h	50,000 h
PCI 50 PRO	н	1x50 W	tc	50 °C	55 °C	60 °C	65 °C	70 °C	75 °C	х
101001110			Lifetime	> 90,000 h	> 90,000 h	> 90,000 h	90,000 h	65.000 h	50,000 h	х
PCI 70 PRO	н	1x70 W	tc	60 °C	65 °C	70 °C	75 °C	х	х	х
101701110			Lifetime	> 90,000 h	90,000 h	65,000 h	50,000 h	х	х	х
PCI 150 PRO	н	1x150 W	tc	70 °C	75 °C	80 °C	х	х	х	х
		11150 W	Lifetime	100,000 h	75,000 h	55,000 h	Х	Х	х	х

Expected lifetime

k ... not permitted

Humidity:

Storage conditions

5 % up to max. 85 %, not condensed (max. 56 days/year at 85 %)

Storage temperature: -40 °C up to max. +80 °C

The devices have to be within the specified temperature range (ta) before they can be operated.